



OFFICE OF THE DEPUTY FIRE OFFICER,
BHAWANIPATNA CIRCLE, KALAHANDI
AT- BHAWANIPATNA FIRE STATION CAMPUS , PO- PARAMANANDAPUR,
BHAWANIPATNA, DIST - KALAHANDI, PIN - 766001
MAIL - dfobptcircle@gmail.com

L. No. 551 / BPT CrI.

Date:26.04.2022

To

Mr. Balaram Mishra
Principal of Kendriya Vidyalaya, Dharamgarh,
At-Govt. High School Campus, Dharamgarh, Kalahandi

Ref:- Your online application No. FSC1410350022022000004, Dtd. 12.04.2022

Sub:- Application for issuance of Fire Safety Certificate against Kendriya Vidyalaya,
Dharamgarh, Govt. High School Campus, Dharamgarh, Dist. - Kalahandi

Sir,

With reference to the above cited subject this is to intimate that the aforesaid premises was inspected by DFO, BPT Circle & SO, Dharamgarh FS on 19.04.2022. As per plan constructed building is 6 Floor educational building having height of 7 mtr & total built-up area is 700 m². You have applied for issuance of Fire Safety Certificate in respect of aforementioned building. As per Rule-9 (1) (i) of Odisha Fire Prevention and Fire Safety Rule-2017 read with Odisha Fire Prevention and Fire Safety Rule (Amendment) -2019 categorized as Educational Establishments as mentioned below required Fire Safety Certificate.

- (i) Having a height of twelve meters and above, or
- (ii) Having a built up area of one thousand square meter or above, or
- (iii) Having three storied building.

As such, the aforementioned Ground floor educational building having height of 7 mtr and total built-up areas is 700 m² is not required Fire Safety Certificate.

However, it is to mention that as regards to Fire Prevention and Fire Safety measures has been taken as per NBCI-2005, you are requested to have provisions as mentioned below:-

1. If any further construction is required to be made, please intimate this office before commencement of the construction work for furtherance at this end.
2. Staff and students need to be trained periodically to make them well conversant in use of the Firefighting equipment for their operation during the time of emergency.

Yours faithfully



(S.Ch. Mallick)

Deputy Fire Officer
Dy. Fire Officer
Bhawanipatna Circle