

**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER,
R.W.S&S SUB DIVISION DHARAMGARH**

Letter No. 465

/Dated/ 27/07/21

To

The Principal
KV Dharamgarh
Kalahandi

Sub - Water Testing Report .

Ref: - Your Letter No. F.320112/KVDGH/2021-22/32 Dt :- 17.07.2021

Sir,

With reference to the cited above, the water testing report of water sample submitted by you to this office is enclosed herewith for your information & necessary action.

Encl :- as above

Yours faithfully,



Assistant Executive Engineer
RWS&S Sub-Division
Dharamgarh

**WATER TESTING REPORT OF RWS&S SUB-DIVISIONAL WATER TESTING
LABORATORY, DHARMAGARH**

KV Dharmagarh	Source	pH Value	Fluoride mg/L	Chloride mg/L	Hardness mg/L as CaCo3	TDS mg/L	Conductivity
	T/W	7.13	0.73	38	122	242.4	380.8

K. Parigrahi
27/02/2021
Lab-Chemist
RWS&S Sub-Divisional
Water Testing Laboratory
Dharmagarh

[Signature]
22/2/21
Assistant Executive Engineer
RWS&S Sub-Division
Dharmagarh